

Property Location: 1057 Gibsons Way
Application Number(s): ZA-2023-03 / DP-2023-13
Date of Referral: 16-Oct-23

Referrals sent	Comments Received
<i>S k w x wú7mesh Úxwumix (Squamish Nation)</i>	<i>No comments received</i>
Gibsons and District Volunteer Fire Department (GDVFD)	<p><i>The Gibsons & District Volunteer Fire Department approves this application with the following recommendations.</i></p> <ol style="list-style-type: none"> <i>1. Fire hydrants are installed in accordance with BCBC 3.2.5.15.</i> <i>2. A water supply in accordance with BCBC 3.2.5.7.</i> <i>3. Standpipe Systems are installed in accordance with BCBC 3.2.5.8.</i> <i>4. Automatic Sprinkler Systems are installed in accordance with BCBC 3.2.5.12.</i> <i>5. Road design is in accordance with BCBC 3.2.5.6.</i> <i>6. Access Routes and Access Route locations are in accordance with BCBC 3.2.5.4. and 3.2.5.5.</i> <i>7. Fire Alarm system to be installed in accordance with BCBC 3.2.4.1.</i> <i>8. Annunciators to be installed in accordance with BCBC 3.2.4.9.</i> <i>9. Roof access design in accordance with BCBC 3.2.5.3.</i> <i>10. A key lock tube is located at or near the front entrance.</i> <i>11. A complete fire safety plan is finished before occupancy is given.</i> <i>12. Standpipe connections are on each landing in the stairwells for fire fighting.</i>
Vancouver Coastal Health	<i>No comments received</i>
Ministry of Transportation and Infrastructure (MOTI)	<i>No comments received</i>
Infrastructure Services Department	<i>No comments received</i>
Building Department	<i>No comments received</i>